



# RESTORE-LITE<sup>®</sup>

TEMPORARY POWER RESTORATION

The cord set is designed to connect the Restore-Lite<sup>®</sup> unit to the power terminal and neutral.

## Installation and operation of Cord Sets:

**P80063** (150 amp connectors) - **P80064** (300 amp connectors)

### Cord set with Crimped Lugs



To  
Restore-  
Lite<sup>®</sup> Unit  
Follow  
Color Code

To House  
Terminal  
Hook Up



**SNC Manufacturing Co., Inc**  
101 West Waukau Avenue, Oshkosh, WI 54902  
800-558-3325 or 920-231-7370 \* FAX 920-231-1090  
Email: [telecom@sncmfg.com](mailto:telecom@sncmfg.com)  
Website: [www.sncmfg.com](http://www.sncmfg.com)

T0600


# 1. Attach external cord to Restore-Lite<sup>®</sup> Case



**Twist Lock  
Connection**

# 2. Attach conductor and Twist to secure.

# 3. Ready for Use



Twist to Lock

Twist to Unlock



**SNC Manufacturing Co., Inc**  
101 West Waukau Avenue, Oshkosh, WI 54902  
800-558-3325 or 920-231-7370 \* FAX 920-231-1090  
Email: [telecom@sncmfg.com](mailto:telecom@sncmfg.com)  
Website: [www.sncmfg.com](http://www.sncmfg.com)  
T0600

